

MULTITECH ENGINEERS

(Govt. Approved 'A' Class Electrical Contractor)

Deals in : All types of Electrical (H.T./L.T.) Installation, Commissioning, Repair & Maintenance Lighting of Industrial & Commercial Buildings, LED Lights. Industrial Automation & Solar Power Solution etc.

A-20, Sandesh Nagar, Kankhal, HARIDWAR (U.K.) - 249408

E-mail : multitech025@gmail.com

Sl. No : MTE 2019-15.

Date : 25/12/2019.

Earthing value measured as on date 25/12/2019.

Location	Earthing Resistance Value in Ω	Status
SCHEMATIC YARD		
TANK No - 1	0.39 Ω	OK
TANK No - 2	0.30 Ω	"
TANK No - 3	0.31 Ω	"
TANK No - 4	0.32 Ω	"
TANK No - 5	0.29 Ω	"
TANK No - 6	0.33 Ω	"
TANK No - 7	0.30 Ω	"
TANK No - 8	0.27 Ω	"
TANK No - 9	0.31 Ω	"
TANK No - 10	0.33 Ω	"
TANK No - 11	0.29 Ω	"
Vent - 1	0.26 Ω	"
Vent - 2	0.30 Ω	"
Vent - 3	0.31 Ω	"
Vent - 4	0.29 Ω	"
Vent - 5	0.289 Ω	"
Vent - 6	0.30 Ω	"
Vent - 7	0.30 Ω	"
Vent - 8	0.32 Ω	"
Vent - 9	0.34 Ω	"
Vent - 10	0.30 Ω	"
Vent - 11	0.26 Ω	"
Pump motor 1	0.09 Ω	"
Pump motor 2	0.34 Ω	"
Pump motor 3	0.312 Ω	"
Pump motor 4	0.323 Ω	"
	0.310 Ω	"

Note : Checked all earthings found OK.
all pumps motor are P & P with proper earthing.